State of Wisconsin Department of Natural Resources dnr.wi.gov

CONSTRUCTION SITE INSPECTION REPORT

Form 3400-187 (rev. 9/04)

Page 1 of 2

Notice: Use of this specific form is voluntary, but the information contained on this form must be collected and kept by the permittee under s. NR 216.48(4), Wis. Adm. Code, for a construction site covered under the General WPDES Construction Site Storm Water Discharge Permit, Permit No. WI-0067831-2. This form is provided for the convenience of the permittee to meet the requirements of s. NR 216.48(4), Wis. Adm. Code. Multiple copies of this form may be made to compile the inspection report.

Inspections of implemented erosion and sediment control best management practices must be performed weekly and within 24 hours after a precipitation event 0.5 inches or greater which results in runoff.

Weekly written reports of all inspections conducted by or for the permittee must be maintained throughout the period of general permit coverage.

The information maintained in accordance with s. NR 216.48 (4) must be submitted to the Department upon request.

Name of Permittee: Boat House Lake Country						
Construction Site Name (Project): The Boat House Lake Country Concord	Construction Site ID No.: WI-S067831-04 FIN 55724					
Location: CTH B 750 west of CTH F		County: Jefferson				
Contractor: Terry's Excavating	Field Office Phone: (414) 322-9481					
Note: Weekly inspection reports, along with erosion control and stormwater management plans, are required to be maintained on site and made available upon request.						
Date of inspection (mm/dd/yy): 09/08/16 Type of inspection □ Other (specify) Name(s) of individe 8:30am Robert J Davy Weather: 74 and overcast, over 1.1 inches of rain over night						
Description of present phase of construction: Grading is going slow. Entrance is in and building play it out seems to be working. Storm sewer complete site. Contractor pumping out basin but pumping	leted. East side of site	e is being stoned. No signs of sediment leaving				

CONSTRUCTION SITE INSPECTION REPORT Form 3400-187 (rev. 9/04) Page 2 of 2

Name of Permittee: Boat House Lake Country						
Construction Site Name (Project): The Boat House Lake Country Concord					Construction Site ID No.: WI-S067831-04 FIN 55724	
Modifications Required	Yes	No	Not Applicable	Comments/Recommendations about the overall effectiveness of the erosion and sediment control measures. Note: For each item checked "Yes", complete the follow-up information on page 2.		
Ditch Checks			х			
Erosion Control Plan		Х				
Erosion Mat			х			
Grading Practices		Х				
Inlet Protection			х			
Mulch			х			
Offsite Sediment			х			
Permanent Seeding			х			
Schedule / Phasing		Х				
Silt Fence		х				
Silt Screen			х			
Sod			Х			
Stabilized Outlet			Х			
Temp. Diversion Channel			Х			
Temp. Settling Basin			Х			
Temporary Seeding			Х			
Tracking Pads		Х				
Turbidity Barrier			Х			
Other (specify) _COMPOST BERM		х				
Use the space below for detailed follow-up action items.						
Exact place of erosion/sediment control and observed condition			Description of any necessary maintenance or repair to erosion/sediment control, including anticipated date of completion			

CONSTRUCTION SITE INSPECTION REPORT Form 3400-187 (rev. 9/04) Page 2 of 2

Name of Permittee: Boat House Lake Country					
Construction Site Name (Project): The Boat House Lake Country Concord		Construction Site ID No.: WI-S067831-04 FIN 55724			