

CONSTRUCTION SITE INSPECTION REPORT
Form 3400-187 (R 02/2025)

Inspection Questions:	Yes	No (Identify Actions Required):	Location/Comments:	Actions Completed by Date & Initials
7. Is the public right of way curb line free of tracked soil and accumulation?	☒	☐ Install tracking pad ☐ Widen/lengthen pad ☐ Amend stone/Add geotextile ☐ Install wheel washing station ☐ Close entrance/exit ☐ Limit traffic across disturbed areas ☐ Sweep road and curb line	USING EXISTING DRIVE	
8. Are wetlands, lakes, streams, ditches, or storm sewers downstream of the site free of sedimentation and turbid water leaving the site? ³	☒	☐ Repair/Replace erosion control ☐ Add sediment controls ☐ Modify operations ☐ Contact DNR to verify extent of cleanup required		
9. Is dewatering and/or vehicle and equipment washing being done in a manner that prevents erosion and sediment discharge?	☐	☐ Install treatment train ☐ Install energy dissipation ☐ Modify discharge location ☐ Modify intake to reduce sediment	NA	
10. Are soil stockpiles existing for more than 7 days covered and stabilized?	☒	☐ Seed ☐ Install mat/mulch/polymer ☐ Cover with tarp/plastic sheeting		
11. Are downstream channels and other downhill areas protected from scour and erosion?	☒	☐ Install energy dissipation at outfall ☐ Install ditch checks ☐ Install slope interruption ☐ Install onsite detention		
12. Are good housekeeping practices or treatment controls in place to prevent the discharge of chemicals, cement, trash, and other materials into wetlands, waterways, storm sewers, ditches, or drainage-ways? ⁴	☒	☐ Properly dispose of trash ☐ Provide concrete washout station ☐ Contact DNR to verify extent of cleanup required		
13. Is the plan reflective of current site operations and does it address all erosion and sediment control issues identified during the inspection?	☒	☐ Revise sequence ☐ Revise sediment control BMP ☐ Revise erosion control BMP ☐ Revise post-construction storm water BMP		
14. Are all areas where construction has temporarily ceased (and will not resume for more than 2 weeks) temporarily stabilized?	☐	☐ Topsoil & seed ☐ Install mat/mulch/polymer ☐ Cover with tarp/plastic sheeting	NA	
15. Are all areas at final grade permanently vegetated or stabilized with other treatments?	☐	☐ Topsoil & seed ☐ Install mat/mulch/polymer ☐ Sod ☐ Install stone base	NA	
16. Have temporary sediment controls been removed in areas of the site that meet the permit definition of 'final stabilization'?	☐	☐ Water to establish vegetation ☐ Repair or reseed areas ☐ Remove temporary practices	NA	

³ If sediment discharge enters a wetland or waterbody, the permittee should consult with DNR staff to determine if sediment cleanup and/or additional control measures are required.

⁴ The permittee shall notify the DNR immediately via the spills hotline at (800)943-0003 of any release or spill of a hazardous substance to the environment in accordance with s. 292.11, Wis. Stats., and ch. NR 706, Wis. Adm. Code.