

CONSTRUCTION SITE INSPECTION REPORT

Form 3400-187 (R 02/2025)

Page 1 of 2

Notice: This form was developed in accordance with s. NR 216.48 Wis. Adm. Code for WPDES permittees' convenience; however, use of this specific form is voluntary. Multiple copies of this form may be made to compile the inspection report. Inspections of the construction site and implemented erosion and sediment control best management practices (BMPs) must be performed weekly and within 24 hours after a rainfall event 0.5 inches or greater.

Construction Site Name and Location (Project, Municipality, and County): THREE OAKS		Site/Facility ID No. (FIN): 601638	
Onsite Contact/Contractor: Roger Timm		Onsite Phone/Cell: (920) 948-4166	
Note: In accordance with s. NR 216.48 (4), Wis. Adm. Code, inspection reports, along with erosion control and storm water management plans, are required to be maintained on site and made available upon request. Repair or replace erosion and sediment control best management practices within 24 hours of an inspection or department notification that repair or replacement is needed. PLEASE PRINT LEGIBLY.			
Date of inspection: 10/22/2026	Time of inspection: Start: 11:00 am End: 11:30 am	Type of inspection: ☒ Weekly ☐ Precipitation Event ☐ Other (specify)	
Weather/Site Conditions: Temp. 71 °F Antecedent Soil Moisture 0.6 inches Last Rainfall Depth: 0.6 inches Last Rainfall Date: 10/16/2026		Describe current phase of construction: basin almost completed, filling lots, and topsoiling Scheduled Final Stabilization Date for Universal Soil Loss Equation (USLE) ¹ : 10/31/2026 Project on Schedule ² ? ☒ Yes ☐ No Inspector Phone/Cell: (262) 366-1633	
Name(s) of individual(s) performing inspection: ROBERT J DAVY			
I certify that the information contained on this form is an accurate assessment of site conditions at the time of inspection:			
Inspector Signature 		Date: 10-22-26	
Inspection Questions:		No (Identify Actions Required):	Location/Comments:
1. Is the erosion control plan accessible to operators?		☒ Provide onsite copy	
2. Is the permit certificate posted where visible?		☒ Post certificate	
3. Is the current phase of construction on sequence with the site-specific erosion and sediment control plan, including installation/stabilization of ponds and ditches?		☒ Add sediment control ☐ Install missing ditch/pipe/pond ☐ Stabilize bare soil	
4. Are all erosion and sediment control BMPs shown on plan properly installed and in functional condition?		☒ Repair ☐ Modify ☐ Install/Replace	
5. Is inlet protection properly installed and functioning in all inlets likely to receive runoff from the site?		☐ Clean ☐ Replace ☐ Install	NA
6. Is the air free of fugitive dust resulting from construction activity and bare soil exposure?		☒ Apply water ☐ Apply dust control product	
			Actions Completed by Date & Initials

¹ The Universal Soil Loss Equation (USLE) model and the Construction Site Soil Loss and Sediment Discharge Guidance are available at: http://dnr.wi.gov/topic/stormwater/standards/const_standards.html
² If the project is not on schedule then the soil loss summary for the project should be reviewed and schedule, plan or practices modified accordingly.

CONSTRUCTION SITE INSPECTION REPORT

Form 3400-187 (R 02/2025)

Inspection Questions:	Yes	No (Identify Actions Required):	Location/Comments:	Actions Completed by Date & Initials
7. Is the public right of way curb line free of tracked soil and accumulation?	☐	☐ Install tracking pad ☐ Widen/lengthen pad ☐ Amend stone/Add geotextile ☐ Install wheel washing station ☐ Close entrance/exit ☐ Limit traffic across disturbed areas ☒ Sweep road and curb line	mud being tracked on road needs to be swept	
8. Are wetlands, lakes, streams, ditches, or storm sewers downstream of the site free of sedimentation and turbid water leaving the site? ³	☐	☒ Repair/Replace erosion control ☐ Add sediment controls ☐ Modify operations ☐ Contact DNR to verify extent of cleanup required	repair silt fence on North east side of site	
9. Is dewatering and/or vehicle and equipment washing being done in a manner that prevents erosion and sediment discharge?	☐	☐ Install treatment train ☐ Install energy dissipation ☐ Modify discharge location ☐ Modify intake to reduce sediment	NA	
10. Are soil stockpiles existing for more than 7 days covered and stabilized?	☒	☐ Seed ☐ Install mat/mulch/polymer ☐ Cover with tarp/plastic sheeting		
11. Are downstream channels and other downhill areas protected from scour and erosion?	☒	☐ Install energy dissipation at outfall ☐ Install ditch checks ☐ Install slope interruption ☐ Install onsite detention		
12. Are good housekeeping practices or treatment controls in place to prevent the discharge of chemicals, cement, trash, and other materials into wetlands, waterways, storm sewers, ditches, or drainage-ways? ⁴	☒	☐ Properly dispose of trash ☐ Provide concrete washout station ☐ Contact DNR to verify extent of cleanup required		
13. Is the plan reflective of current site operations and does it address all erosion and sediment control issues identified during the inspection?	☒	☐ Revise sequence ☐ Revise sediment control BMP ☐ Revise erosion control BMP ☐ Revise post-construction storm water BMP		
14. Are all areas where construction has temporarily ceased (and will not resume for more than 2 weeks) temporarily stabilized?	☐	☐ Topsoil & seed ☐ Install mat/mulch/polymer ☐ Cover with tarp/plastic sheeting	NA	
15. Are all areas at final grade permanently vegetated or stabilized with other treatments?	☐	☐ Topsoil & seed ☐ Install mat/mulch/polymer ☐ Sod ☐ Install stone base	NA	
16. Have temporary sediment controls been removed in areas of the site that meet the permit definition of "final stabilization"?	☐	☐ Water to establish vegetation ☐ Repair or reseed areas ☐ Remove temporary practices	NA	

³ If sediment discharge enters a wetland or waterbody, the permittee should consult with DNR staff to determine if sediment cleanup and/or additional control measures are required.

⁴ The permittee shall notify the DNR immediately via the spills hotline at (800)943-0003 of any release or spill of a hazardous substance to the environment in accordance with s. 292.11, Wis. Stats., and ch. NR 706, Wis. Adm. Code.